



NOTES:

1. LENGTH OF EXTENSION OF PIPE AND RESTRAINED JOINTS SHALL BE IN ACCORDANCE WITH THESE ENGINEERING STANDARDS.
2. ALL WATER MAINS TWELVE (12") INCHES OR SMALLER, WHICH CROSS UNDER DENVER WATER CONDUITS SHALL BE DUCTILE IRON.
3. CATHODIC PROTECTION SHALL BE AS REQUIRED IN ACCORDANCE WITH THESE ENGINEERING STANDARDS.
4. A BORED CROSSING MAY BE REQUIRED BY THE ENGINEER.

DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204
Phone (303) 628-6000 • Telecopier No. (303) 628-6851



**OPEN CUT CROSSING
BENEATH CONDUIT**

Scale: NONE Date: JULY 1995

Drawn: C.B.B. Tr: Ck:

Approved: Dr. 127 No. 35